

Determination of Absorption of Mortar

Date : 30/12/2007

Client: شركة كويك ميكس (عناية م / خالد بسيوني)

Description of sample: مونة محارة من الإسمنت البطل ، رمل عجمي ، ومادة super soft .

Delivery Date: 10/12/2007

Testing Date: 23/12/2007


Remark: Materials were delivered by the client on his responsibility.

Note: Sample was taken and delivered by the client.

Results of Sample No. (1) :

- Absorption = 5.96%

Tested by




Karem Mahrous,
Lab. Tech

Checked by



Eng. Ahmed Mokhtar,
Lab. Engineer

Approved by
المركز المصري للإختبارات
Dr. 
ETC
Egyptian Testing Center



Determination of Absorption of Mortar

Date : 30/12/2007

Client: شركة كديك ميكس (عناية م/ خالد بسيوني)

Description of sample: مونة محارة مكونة من أسمنت ابيض , رمل عجمي .

Delivery Date: 10/12/2007

Casting Date: 10/12/2007

Remark: Materials were delivered by the client on his responsibility.

Note: Sample was taken and delivered by the client.

Results of Sample No. (4) :

- Absorption = 6.68%

Tested by



Karem Mahrous,
Lab. Tech

Checked by



Eng. Ahmed Mokhtar,
Lab. Engineer

